

Advocacy Report - ICC 2021 Cycle Group A ICC HCC Proposals

#	K-Tag	ICC Code Proposal #	Proposed Modification	Status		
				CAH	PC	PCH
1	K224	E045	Manual horizontal sliding doors	●		
2	K222-P1	E052	Manual locking provision - Staff Keys	●		
3	K221-P1	E055	Controlled egress doors - smoke detector	●		
4	K221-P2	E057	Controlled egress doors - cognitive	●		
5	K222-P2	E059	Delayed egress locking system exceptions	●		
6	K222-P3	E061	Emergency lighting egress side of door	●		
7	P5	E092	Transfer air for both positive and negative pressure rooms	●		
8	P1-P3	E123	Accessible units in Group I-1, Condition 1 & 2 Exceptions - not more than 50% water closets and roll in showers required to comply with ICC A117.1	●		
9	P1-P4	E124	Accessible units in Group I-2 Nursing homes Exceptions - not more than 90% water closets and roll in showers required to comply with ICC A117.1	●		
10	P1-P5	E125	Accessible units in Group I-2 Rehab Facs Exceptions - not more than 50% water closets and roll in showers required to comply with ICC A117.1	●		
11	P1-P1	E128	Assisted toileting and bathing - equivalent facilitation to the accessible toilet requirement in ICC A117.1 and the 2010 ADA Standard	●		
12	P1-P2	E129	Assisted toileting and bathing - removal of the requirement for permanently installed folding or fixed seats	●		
13	K741	F012	Patient smoking based on clinical need	●		
14	K711, K712-P01	F024	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - moves specific ambulatory care facility criteria so that it is a subset of Group B	●		
15	K711, K712-P02	F025	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - consistent use of care recipient instead of patient	●		
16	K711, K712-P03	F026	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - "location of special locking arrangements".	●		
17	K711, k712-P04	F027	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - consistent use of staff vs employee	●		
18	K711, K712-P09	F028	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - clarification of drill requirements	●		
19	K711, K712-P06	F030	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - resident training clarification	●		

20	K711, K712-P07	F031	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - consistent use of staff vs employee	●		
21	K711, K712-P08	F032	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - allow for the timing of fire drills to not be “unexpected time and under varying conditions”	●		
22	K933	F033	Fire loss prevention in ORs	●		
23	K711, K712-P10	F039	Coordination of fire safety, evacuation and lock down plans for I-1, I-2, I-3, R-4 & Amb Care facilities - coordination of lock down plans	●		
24	K913	F069	Electrical systems and equipment must be maintenance and testing requirements listed in NFPA 99	●		
25	K920	F073	RPT requirements	●		
26	K346, K354	F101	AASS out of service per NFPA 25/72 Exception	●		
27	K524-P1	F122 - P1	QR heads in smoke compartment with gas/decorative fireplaces	●		
28	K524-P2	F122 - P2	Exclusion of gas fireplaces in patient sleeping rooms	●		
29	K711, K712-P11	F147	Exception for both visible and audible alarms in hospitals	●		
30	K211	F180	Removal of wheeled equipment	●		
31	K363	F188	Corridor door clearances, hold opens and protective plates	●		
32	K241	F189	MOE without return to compartment	●		
33	K918	F192	Inspection and testing requirements of emergency and standby power systems per NFPA 99	●		
34	K322	F271	Align hospital labs with academic research labs	●		
35	P3	F282	High-rise requirements for storage of gases in high-rise I-2 occupancies	●		
36	K925	F286	Restriction of sources of ignition in RT Areas	●		
37	K926	F295	Training requirements of medical gas systems and associated equipment and cylinders	●		
38	K909, K924, K928	F297 - P1	Clarifies that the application of NFPA 99 includes the use, testing and labeling of medical gas systems and equipment	●		
39	K909, K924, K928	F297 - P2	Clarifies that the application of NFPA 99 includes the use, testing and labeling of medical gas systems and equipment	●		
40	K372	FS038	Smoke compartment definition and clarification of boundaries	●		
41	K364	FS039	Pass thru opening requirements	●		
42	P4	FS067	More accurately reflect typical installations of fully ducted systems	●		

43	K331	FS086	Lockers considered interior finish	●		
44	K324-P1	G040	Separate the requirements for domestic cooking appliances and exhaust from the allowance for that area to be open to the corridor in a nursing home	●		
45	K324-P2	G041	Exceptions for domestic cooking	●		
46	K362	G042	Non-rated doors in corridors requirements	●		
47	K256, K257	G043	Exit access options from a suite	●		
48	K255	G044	Removal of distance of travel exception	●		
49	K223	G046	Automatic release of hold opens	●		
50	K324-P3	G055	Separate the requirements for domestic cooking appliances and exhaust from the allowance for that area to be open to the corridor in an assisted living facility.	●		
51	K324-P4	G056	Exceptions applicable to cooktops and ranges.	●		
52	K324-P7	G058	Domestic cooking training facilities Amb Care	●		
53	P6	G087	Use of non-separated mixed uses in hospitals	●		
54	K163	G112	Fire retardant-treated wood in shaft enclosures	●		
55	K162	G113	Fire retardant-treated wood in roof construction	●		
56	K521	M031	HVAC for I-2 & Amb Care meet 170 & 99	●		
57	K324-P6	M050	Allow recirculating hoods in I-1 & I-2	●		
58	K324-P5	M051	Address circular reference and coordinate with IBC & IFC changes	●		
59	K523	M081	Suspended heaters not allowed in MOE	●		
60	P2	P100	2 Water service pipes	●		

Legend:

Yellow Filled Cell = Proposals drafted by General/Mean of Egress Work Group

Cyan Filled Cell = Proposals drafted by MEP Work Group

Green Filled Cell = Proposals drafted by Fire/Fire Safety Work Group

CAH = Code Action Hearings

● = Approved as Submitted, ● = Approved as Modified, ● = Disapproved

PC = Public Comment

● = Submitted by ICC HCC, ● = Submitted by Others

PCH = Public Comment Hearings

● = Approved as Submitted, ● = Approved as Modified, ● = Disapproved